

Diris Digiware: TCP port list to open

When **energy** matters



When **energy** matters

 **socomec**
Innovative Power Solutions

This information note aims to list the different TCP ports to open in the LAN where a Diris Digiware D/M-xx gateway is installed. Opening the ports listed below is strongly recommended to ensure optimal operation of the metering system.

TCP PORT LIST TO OPEN

Port 80 for browsing on Webview-M/Web-config web server in **HTTP**

Port 443 for browsing on Webview-M/Web-config web server in **HTTPS**

Port 502 and 503 for **Modbus TCP/IP** requests

Port 1900 for **SSDP** (auto-discovery of gateways with the Easy Config System configuration software or Webview-L)

Port 123 for time synchronization with an **SNTP** server

Port 47808 for communication in **BACnet IP**. This port can be modified through Webview-M/Web-config in the settings, "Protocols" menu, "Field protocols" tile

Port 21 for sending data to an **FTP** server

Port 990 for sending data to an **FTPS** server

Port 25 for sending emails via an **SMTP** server

Port 587 and 465 for sending emails via an **SMTPS** server

Port 161 and 162 for **SNMP** communication

Port 1883 for **MQTT** cloud

HEAD OFFICE

SOCOMEK GROUP

SAS SOCOMEK capital 10749940 €
R.C.S. Strasbourg B 548 500 149
B.P. 60010 - 1, rue de Westhouse
F-67235 Benfeld Cedex
Tel. +33 3 88 57 41 41 - Fax +33 3 88 57 78 78
info.scp.isd@socomec.com

YOUR DISTRIBUTOR / PARTNER

www.socomec.com

